



NC DEPARTMENT OF  
**HEALTH AND  
HUMAN SERVICES**

**JOSH STEIN** • Governor

**DEVPUTTA SANGVAI** • Secretary

**KAREN BURKES** • Acting Deputy Secretary for Health

**KELLY KIMPLE** • Acting Director, Division of Public Health

March 7, 2025

Mr. David Simon  
Valencia Pipe Company  
28305 Livingston Ave  
Valencia, CA 91355

Subject: Approval of plans and specifications for a 1,500 gallon septic tank

Dear Mr. Simon:

Plans and specifications for the above-referenced new tanks have been reviewed and found acceptable by the On-Site Water Protection Branch and are approved under the On-Site Water Protection approval numbers: STB-2166 for the 1,500 gallon septic tank.

The imprints that will identify the manufacturer, serial number, and capacity of the referenced tanks will be: VPC-STB-2166-1500 for the 1,500 gallon septic tank. The imprints shall be located to the right of the knockout made on the outlet end of the septic tank.

One copy of each set of plans and specifications bearing the On-Site Water Protection stamp of approval is enclosed. Once copy is being retained in our permanent files.

Effluent filters, outlet pipe penetration seals, risers, and all other appurtenances must be state approved and installed as per the approved plans and specifications. This approval applies only to tanks constructed in accordance with their approved plans and specifications. If the tank is found to be out of compliance, an Operation Permit will not be issued for the installed wastewater system. Tanks shall be watertight and may be subject to a watertightness test, per local and state environmental health guidelines.

All tank manufacturers having North Carolina state approval of septic or pump tanks are subject to periodic, unannounced inspections of their tanks and manufacturing process by state and local environmental health officials. Tanks found not in compliance with their state-approved plans or 15A NCAC 18E may be permanently identified as being unacceptable for use in North Carolina on-site wastewater systems and the manufacturer of such tanks may face suspension or revocation of state approval for their tanks.

If you have any questions pertaining to this approval or if we may be of further service, please feel free to contact me at 919-218-2580 or [trish.angoli@dhhs.nc.gov](mailto:trish.angoli@dhhs.nc.gov).

Sincerely,

Tricia Angoli, PE  
On-Site Wastewater Engineering

Enclosures

**NC DEPARTMENT OF HEALTH AND HUMAN SERVICES • DIVISION OF PUBLIC HEALTH**

LOCATION: 5605 Six Forks Road, Building 3, Raleigh, NC 27609  
MAILING ADDRESS: 1642 Mail Service Center, Raleigh, NC 27699-1642  
[www.ncdhhs.gov](http://www.ncdhhs.gov) • TEL: 919-707-5874 • FAX: 919-845-3972

AN EQUAL OPPORTUNITY / AFFIRMATIVE ACTION EMPLOYER