



COMMONWEALTH of VIRGINIA

Department of Health  
P O BOX 2448  
RICHMOND, VA 23218

TTY 7-1-1 OR  
1-800-828-1120

Karen Shelton, MD  
State Health Commissioner

R. Christopher Lindsay  
Chief Operating Officer

June 28, 2024

Mr. Samuel C Hampsher-Monk  
[compliance@vpcglobal.com](mailto:compliance@vpcglobal.com)  
VPCglobal.com

Dear Mr. Hampsher-Monk,

On May 16, 2024 you submitted documentation on the following septic tanks for approval by the Virginia Department of Health, Office of Environmental Health, Division of Water and Wastewater Services.

Model Number	Description
87-41718	1000 Gallon Single Compartment Septic Tank Yellow
87-41720	1000 Gallon Two Compartment Septic Tank Yellow
87-41758	1500 Gallon Single Compartment Septic Tank Yellow
87-41760	1500 Gallon Two Compartment Septic Tank Yellow

The subject tanks do not meet the following Sewage Handling and Disposal Regulations (12VAC5-610-815) criteria:

1-2 inch difference between inverts of inlet and outlet structures (3 inches provided)

However, after reviewing the information provided by VPC global, the Office of Environmental Health Services approves the tank for use in Virginia when used with an NSF-certified effluent filter.

Sincerely,

Lance Gregory  
Director  
Division of Onsite Water and Wastewater Services