



STATE OF WASHINGTON
DEPARTMENT OF HEALTH
OFFICE of ENVIRONMENTAL HEALTH and SAFETY
wastewatermgmt@doh.wa.gov
PO Box 47824, Olympia, WA 98504
(360) 236-3330 ■ 711 Washington Relay Service

July 24, 2024

Chris Butler
VPC Global
28305 Livingston Avenue
Valencia, CA 91355

Re: Application for VPC Global Septic Tanks: 1000 Gallon Two Compartment Septic Tank Yellow, 1000 Gallon Single Compartment Yellow, 1500 Gallon Two Compartment Septic Tank Yellow, 1500 Gallon Single Compartment Septic Tank Yellow

Dear Chris Butler:

Thank you for submitting your on-site sewage system tank registration application for the tanks listed above. The Department of Health, in accordance with chapter 246-272C WAC, On-site Sewage System Tanks, has reviewed your application. Based on the information provided, the tanks listed above meet the requirements for on-site sewage system tanks registration. Therefore, when next updated, your tanks will be placed on List of Registered On-site Sewage System Tanks as shown on the attached table.

Registration for these tanks expires on December 31, 2027. If you wish them to remain registered after that time, you must follow the requirements in WAC 246-272C-0140 and send your renewal paperwork in one month before the expiration date. If the department finds that the product has changed in any way that affects its performance, it may be removed from the registered tank list before the expiration date, or the registration won't be renewed -- and must again meet the requirements for initial registration. If you have any questions, please contact Andrew Jones at (360) 236-3378 or by email at andrew.jones@doh.wa.gov.

Sincerely,

Andrew Jones, P.E.
LOSS & Reclaimed Water Program Supervisor

Enclosure: Table to be published in list

Manufacturer	Model Number	Tank Size (gallons)	Number of Compartment	Usage	Date Approved	Limitations
VPC Global 28305 Livingston Ave. Valencia, CA 91355 Tank Material: Polyethylene	1000 Gallon Single 1000 Gallon Double 1500 Gallon Single 1500 Gallon Double	1000 1000 1500 1500	Single Double Single Double	Septic Tank	7-23-2024 / 12-31-2027	Maximum bury depth of 30" above the top of the tank. Refer to installation instructions if groundwater above base of tank.